

SAN JOSE SHELTER FOR THE HOMELESS


COST FREE CLARIFICATION

Maxim Schrogin  
Oliver and Co.,  
1035 Carleton Street,  
Berkeley 94710.

CLARIFICATION no: 51  
Date: 2/17/89


REGARDING Reinforcing details for Gunnite Truss

This clarification is issued in accordance division 1, section 1.7 of the contract specifications, for the purpose of clarifying the drawings and/or specifications. This clarification shall in no event result in an increased cost.



All #10 web bars are bent with 12" tails which parallel main axis of cord.

#2 stirrups can be tack welded to a #3 top and/or bottom to allow for simpler installation of steel. No welds on <sup>any</sup> longitudinal #4 bars.



SIGNATURE

[Signature]  
For CES

For Oliver and Company



SAN JOSE SHELTER FOR THE HOMELESS

COST FREE CLARIFICATION

Maxim Schrogin  
Oliver and Co.,  
1035 Carleton Street,  
Berkeley 94710.


CLARIFICATION no: 51 (a.)  
Date: 3/2/89

REGARDING Reinforcing details for Gunnite Truss

This clarification is issued in accordance division 1, section 1.7 of the contract specifications, for the purpose of clarifying the drawings and/or specifications. This clarification shall in no event result in an increased cost.

#2 stirrups in cages of main chords can be tack welded to a #3 bar, top and/or bottom, to allow for simpler installation of steel. The #3 bars are in addition to the #4 bars of the cages. There are to be no welds on any longitudinal #4 bars.

#2 stirrup



SIGNATURE

[Signature]  
For CES

For Oliver and Company